

## **COMPRESSOR DATA SHEET**





	MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	BOGE Kompressoren GmbH & Ko.KG							
	Model No:	C 9		Date:	21.07.2025				
2	х	X Air Cooled							
		Water Cooled		# of Stages:	1				
		Other Please State:							
3*	Rated Capacity	at Full Load Operating Pressure <sup>a,e</sup>	1,19	<b>19</b> m <sup>3</sup> /min <sup>a,e</sup>					
4*	Full Load Operating Pressure b 7,00				bar g <sup>b</sup>				
5	Maximum Full F	1aximum Full Flow Operating Pressure c 8,00 bar g b		rg <sup>b</sup>					
6	Drive Motor Nor	Prive Motor Nominal Rating 7,50		kW					
7	Drive Motor Nor	Drive Motor Nominal Efficiency 90,10		% (percent)					
8	Fan Motor Nominal Rating (if applicable)			kW					
9	Fan Motor Nominal Efficiency			% (percent)					
10*	Total Package Input Power at Zero Flow <sup>e</sup> 1,65		1,65	kW <sup>e</sup>					
11	Total Package Input Power at Rated Capacity and Full Load  Operating Pressure d  8,93		kW <sup>d</sup>						
12	Package Specifi	Package Specific Power at Rated Capacity and Full Load Operating Pressure e 7,54		kW/m3/min <sup>e</sup>					
13	Isentropic Effici	ency	62,80	% (percent)					

## Notes:

- a. Measured at the discharge terminal point of the compressor in accordance with ISO1217, Annex E; m³/min is cubic metres per minute at inlet conditions.
- b. The operating pressure at which the capacity (item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load / no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
  The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m³/min	%	%	%	
Below 0.5	+/-7	+/-8	+/- 10	
0.5 to 1.5	+/-6	+/-7		
1.5 to 15	+/- 5	+/-6		
Above 15	+/- 4	+/- 5		

<sup>\*</sup>For models that are tested in the BCAS Data Sheet & Verification Programme, these items are verified by the third party administrator. Consult BCAS website for a list of participants in the third party verification programme: www.bcas.org.uk