

PERFORMANCE VERIFICATION PROGRAMME DATA SHEET



ROTARY COMPRESSOR: VARIABLE SPEED / FREQUENCY DRIVE

| MODEL DATA - FOR COMPRESSED AIR | | | | | | | | | |
|---------------------------------|--|--------------------|---------------------|---|-------------------------------|---------------------------------|-------------------------------|--|--|
| 1 | Manufacturer: | CompAir | | | | | | | |
| 2 | Model No: | L07e RS Air Cooled | | | | Date: | 01.08.2024 Regulated Speed | | |
| | Water Cooled | | | | | # of Stages: | 1 | | |
| | | Other | Please State: | | | | | | |
| 3 | Full Load Operating Pressure | | | 6 | bar g | | | | |
| 4 | Drive Motor Nominal Rating | | | 7.5 | kW | | | | |
| 5 | Drive Motor Nominal Efficiency | | | 90.1 | % (percent) | | | | |
| 6 | Fan Motor Nominal Rating (if applicable) | | | n/a | kW | | | | |
| 7 | Fan Motor Nominal Efficiency | | | n/a | % (percent) | | | | |
| 8 | Range | | Input Power (kW) | Capacity (m3/min) | Specific Power (kW/m³/min) | Isentropic Efficiency (%) | | | |
| | Maximum Speed 100% | | 8.63 | 1.28 | 6.74 | 64.34% | 1 | | |
| | 7.69 | | | 1.12 | 6.87 | 63.17% | | | |
| | | | 6.74 | 0.97 | 6.95 | 62.43% | | | |
| | | | 5.84 | 0.81 | 7.21 | 60.16% | | | |
| | Minimur | n Speed | 4.24 | 0.5 | 8.48 | 51.15% |] | | |
| 9 | Total Package Input Power at Zero Flow | | 1.3 | kW | | | | | |
| 10 | Specific Power (KW/m3/min) 2 9 2 8 6 | .00 | | 0.4 0.6 Capacity (m³/min) nly a visual representation of the data | in Section 8 | 1 1. | 2 1.4 | | |

^{*}For models that are tested in the BCAS Data Sheet & Verification Programme, these items are verified by the third party administrator. Consult BCAS website for a list of participants in the third party verification programme: www.bcas.org.uk

Notes:

- a. Measured at the discharge terminal point of the compressor in accordance with ISO1217, Annex E; m³/min is cubic metres per minute at inlet conditions.
- b. The operating pressure at which the capacity (item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power in accordance with ISO1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO1217, Annex E, as shown in table below:
- e. The terms "power" and "energy" are synonymous for purposes of this document.

| Volume Flow Rate at specified conditions | Volume Flow Rate | Specific Energy Consumption | No Load / Zero Flow Power | | | | |
|---|---------------------|-----------------------------------|------------------------------|--|--|--|--|
| m³/min | % | % | % | | | | |
| Below 0.5 | +/- 7 | +/- 8 | | | | | |
| 0.5 to 1.5 | +/- 6 | +/- 7 | +/- 10 | | | | |
| 1.5 to 15 | +/- 5 | +/- 6 | | | | | |
| Above 15 | +/- 4 | +/- 5 | | | | | |